

233 East Main Street Middletown, NY 10940 Phone: (845)344-5863 Fax: (845)956-5865

Consulting Engineers

Alfred A. Fusco, Jr. P.E. Principal Alfred A. Fusco, III General Manager

November 19, 2024

Solomon Weiss, Planning Board Chairman Village of South Blooming Grove 811 NYS Route 208 Monroe, NY 10940

Project: 6 Sears Road SBL: 216-1-3

Material Reviewed: Plan prepared by Joseph Medic, P.E. revised 9/30/24

Our File: SBG-198

Dear Chairman Weiss,

We have reviewed the plan prepared by DrawME and offer the following:

- 1. Please verify whether the plan has been submitted to SHPO. The plan was submitted to SHPO.
- 2. Please verify that the retaining walls provided can be constructed based on the distance from the property line and the geogrid required for an 8' tall wall.

The Geogrid will be placed away from the property line because lower elevation is where the property line is

3. Please note that plans have been provided to the building department for review for a building permit. A full building permit application based on a plan approved by the Planning Board must be submitted along with the appropriate building permit application, application fees, and escrow if required.

Noted. Thank you.

Please advise if you have any questions.

Very truly yours,

Alfred A. Fusco, Jr., P.E. Fusco Engineering & Land Surveying, D.P.C.

Cc: Tom Shepstone

Issac Ekstein, VOSBG
Joel Stern, VOSBG
Daniel Kraushaar, Esq.
Todd Maurizzio, FE&LS
Efrain Baez, FE&LS
Alfred A. Fusco, Jr., P.E., FE&LS

Kerry Dougherty, Clerk